



ಹುಬ್ಬಳ್ಳಿ ಧಾರವಾಡ
HUBBALLI DHARWAD



ಸ್ಮಾರ್ಟ್ ಸಿಟಿ ಲಿಮಿಟೆಡ್
SMART CITY LIMITED



Special Purpose Vehicle for Implimentation of Smart City Project
(Registered Company No. CIN : U74999KA2017 PLC 101265)

HDSCL/SCP/QUOTATION/MD/2025/

Date: 21.02.2024

Quotation Notification

Advt No.02/2024-25 / Date: 21.02.2025

- 1) The Managing Director Hubballi-Dharwad Smart City (HDSCL), on behalf of Hubballi-Dharwad Smart City Limited Invites the Quotation for Janta Bazar Ground floor Electrical repair and reinstallation of wiring and damaged conduit pipes including complete labour and bringing it back to working condition
- 2) The bidders have to provide a Quotation in the name of Managing Director, Hubballi Dharwad Smart city Limited.
- 3) For further details please contact Assistant Executive Engineer, Hubballi-Dharwad Smart City Limited, Hubballi during the Office hours on Telephone No: 0836-2355331 and 2355322,
- 4) Last date for submission of quotation: 24.02.2025

Sl. No	Name of the Work	Last Dated for submission of quotation
01	Janta bazar Building Ground Floor shops general facility electrical service wiring and reinstallation damaged conduit pipes, LED Lights /repair works and connections for working good condition including material and labour as per the Electrical repair Annexure- A	On or Before 24.02.2025

ELECTRICAL REPAIR WORKS ANNEXURE-A QUOTES INVITATION			
SL NO.	PARTICULARS	Unit	Quantity
1	Supplying and wiring adopting loop system in existing PVC Conduit /casingcappingcasingcappingusing2x1.5sqmm(Phase &Neutral) &1x1.0 sqmm (Earth wire) FRLSmulti strand PVC insulated copper wire (confirmingtoIS-694: andlatest amendments)without control switch shall be fixed on the existing plastic sheet/gang box, the other end of the wires shall be terminated with sufficient loose length in a wood/PVC round block. complete for each outlet. Short point upto 3Mtr from tapping point to out let via switch box	Point	45

ನೋಂದಾಯಿತ ಕಛೇರಿ : 4ನೇ ಮಹಡಿ, 'ಎಫ್' ಬ್ಲಾಕ್, ಐಟಿ ಪಾರ್ಕ್, ಹುಬ್ಬಳ್ಳಿ ಕರ್ನಾಟಕ ರಾಜ್ಯ ಭಾರತ,
Regd Office : 4th Floor, 'F' Block, IT Park, HUBBALLI - 580 020, Karnataka State, India.
Ph : 0836-2355322, Fax : 0836-2355331, Control Room Assistance : 2213888/2213898,
Website : www.hubballidharwadsmartcity.com E-mail : smartcityhubballidharwad@gmail.com



ಹುಬ್ಬಳ್ಳಿ ಧಾರವಾಡ
HUBBALLI DHARWAD



ಸ್ಮಾರ್ಟ್ ಸಿಟಿ ಲಿಮಿಟೆಡ್
SMART CITY LIMITED



Special Purpose Vehicle for Implimentation of Smart City Project
(Registered Company No. CIN : U74999KA2017 PLC 101265)

ELECTRICAL REPAIR WORKS ANNEXURE-A QUOTES INVITATION			
SL NO.	PARTICULARS	Unit	Quantity
2	Supplying and wiring adopting loop system in existing PVC Conduit /casing capping using 2x1.5 Sqmm (Phase & Neutral) & 1x1.0 sqmm (Earthwire) FRLS multi strand PVC insulated copper wire (confirming to IS-694: and latest amendments) without control switch shall be fixed on the existing plastic sheet/gang box, the other end of the wires shall be terminated with sufficient loose length in a wood/PVC round block. complete for each outlet. Two outlet in a row, above 3Mtr up to 6Mtr from tapping point to outlet via switches.	Point	40
3	Supplying and wiring adopting loop system in existing PVC Conduit /casing capping using 2x1.5 Sqmm (Phase & Neutral) & 1x1.0 sqmm (Earthwire) FRLS multi strand PVC insulated copper wire (confirming to IS-694: and latest amendments) without control switch shall be fixed on the existing plastic sheet/gang box, the other end of the wires shall be terminated with sufficient loose length in a wood/PVC round block. complete for each outlet. Long point above 6Mtr up to 10Mtr from tapping point to outlet via switch box	Point	40
4	Supplying and wiring adopting loop system in existing PVC Conduit /casing capping using 2x1.5 Sqmm (Phase & Neutral) & 1x1.0 sqmm (Earthwire) FRLS multi strand PVC insulated copper wire (confirming to IS-694: and latest amendments) without control switch shall be fixed on the existing plastic sheet/gang box, the other end of the wires shall be terminated with sufficient loose length in a wood/PVC round block. complete for each outlet. to outlet via switch box	Point	35
5	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V grade, multi strand copper wire with low conductor resistance single core in open or concealed system of wiring with specified IS 694:2010 FRLSH Wires 1.5 Sq.mm	mtr	900
6	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V grade, multi strand copper wire with low conductor resistance single core in open or concealed system of wiring with specified IS 694:2010 FRLSH Wires 2.5 Sq.mm	mtr	950
7	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V grade, multi strand copper wire with low conductor resistance single core in open or concealed system of wiring with specified IS 694:2010 FRLSH Wires 4 Sq.mm	mtr	800
8	Supplying heavy gauge PVC conduit pipe 19/20 mm dia 2 mm thick confirming to IS 2509 with suitable size bends, junction boxes, adhesive paste etc , and fixing using inverted wood plugs in case of RCC ceiling and RCC wall/ stone structure or raw l plugs in case of brick walls and cement plastering the damaged portion using heavy gauge saddles at an interval of 700mm using NF screws.	mtr	1400

ನೋಂದಾಯಿತ ಕಛೇರಿ : 4ನೇ ಮಹಡಿ, 'ಎಫ್' ಬ್ಲಾಕ್, ಐಟಿ ಪಾರ್ಕ್, ಹುಬ್ಬಳ್ಳಿ ಕರ್ನಾಟಕ ರಾಜ್ಯ ಭಾರತ,

Regd Office : 4th Floor, 'F' Block, IT Park, HUBBALLI - 580 020, Karnataka State, India.

Ph : 0836-2355322, Fax : 0836-2355331, Control Room Assistance : 2213888/2213898,

Website : www.hubballidharwadsmartcity.com E-mail : smartcityhubballidharwad@gmail.com



ಹುಬ್ಬಳ್ಳಿ ಧಾರವಾಡ
HUBBALLI DHARWAD



ಸ್ಮಾರ್ಟ್ ಸಿಟಿ ಲಿಮಿಟೆಡ್
SMART CITY LIMITED



Special Purpose Vehicle for Implimentation of Smart City Project
(Registered Company No. CIN : U74999KA2017 PLC 101265)

ELECTRICAL REPAIR WORKS ANNEXURE-A QUOTES INVITATION			
SL NO.	PARTICULARS	Unit	Quantity
9	Supplying and fixing regular MCB distribution boards on wall/Woodn board/ flush mounting using required clamps, bolts, nuts etc., with provision for fixing suitable type capacity MCB's single phase/3 phase/single door with powder coated painting Made out of 14SWG MS enclosure. 12 way DP	nos	6
10	Supplying &fixing miniature circuit breakers on existing MCB distribution boards using necessary fixing materials and 'C' Type curve, indicator ON/OFF, energycross-3 with Short circuit breaking capacityof10Kandcomplete wiring as required confirming to IEC 60898. TPN MCB 63 A	nos	6
11	Supplying &fixing miniature circuit breakers on existing MCB distribution boards using necessary fixing materials and 'C' Type curve, indicator ON/OFF, energycross-3 with Short circuit breaking capacityof10Kandcomplete wiring as required confirming to IEC 60898. 6-32 A SP	nos	50
12	Supplying and fixing surface/flush mounting unbreakable PVC modular box suitable for mounting modular switch plates with due groove cutting in Brick/C.Cwall, including necessary rawl plugs, Machine/NF screws etc., complete. 18 Module box & plate	nos	12
13	Supplying and fixing surface/flush mounting unbreakable PVC modular box suitable for mounting modular switch plates with due groove cutting in Brick/C.Cwall, including necessary rawl plugs, Machine/NF screws etc., complete. 8 Module box & plate	nos	9
14	Supplying and fixing surface/flush mounting unbreakable PVC modular box suitable for mounting modular switch plates with due groove cutting in Brick/C.Cwall, including necessary rawl plugs, Machine/NF screws etc., complete.	nos	8
15	Supplying And fixing/replacing of 6/16/32A electrical accessories on existing switch board. 6 A Socket	nos	20
16	Supplying And fixing/replacing of 6/16/32A electrical accessories on existing switch board. 6 A Switch	nos	50
17	Supplying of.....feet-PVC Batten with integrated LED tubeW with high quality diffuserwithLifeof25000 burninghours&70% lumen maintenance with CRI > 80. Power Input: 220-240V@ 50/60Hz&Power factor >0.9 along with CE approved. 2 years Warranty against any manufacturing defect working under standard electrical condition.	nos	70

ನೋಂದಾಯಿತ ಕಛೇರಿ : 4ನೇ ಮಹಡಿ, 'ಎಫ್' ಬ್ಲಾಕ್, ಐಟಿ ಪಾರ್ಕ್, ಹುಬ್ಬಳ್ಳಿ ಕರ್ನಾಟಕ ರಾಜ್ಯ ಭಾರತ,

Regd Office : 4th Floor, 'F' Block, IT Park, HUBBALLI - 580 020, Karnataka State, India.

Ph : 0836-2355322, Fax : 0836-2355331, Control Room Assistance : 2213888/2213898,

Website : www.hubballidharwadsmartcity.com E-mail : smartcityhubballidharwad@gmail.com



ಹುಬ್ಬಳ್ಳಿ ಧಾರವಾಡ
HUBBALLI DHARWAD



ಸ್ಮಾರ್ಟ್ ಸಿಟಿ ಲಿಮಿಟೆಡ್
SMART CITY LIMITED



Special Purpose Vehicle for Implimentation of Smart City Project
(Registered Company No. CIN : U74999KA2017 PLC 101265)

ELECTRICAL REPAIR WORKS ANNEXURE-A QUOTES INVITATION

SL NO.	PARTICULARS	Unit	Quantity
18	<p>Supplying of recess mounting non integrated type LED down light..... W luminaire comprising of pressure decast/ extruded aluminum housing, with spring loaded false ceiling clamps, LED of Power/COB withCCT6500degreeK,CRI>70%. Efficacy>100 lumen per W, 120degree beam spread, life>25000 burning hours and Compliance toIS10322/IEC60598,LM79&LM80.The lamp compartment is enclosed with anti-glare opal diffuser which enhance sthelighting level. LED's are driven by HF electronic driver integrated in separate control gear assembly., with PF>0.95,power loss hold<5%oflampWage,shortcircuit&opencircuitprotection tobeintegratedinthecircuit,THDlessthan20%,LifeasperLM79.</p> <p>The operating input voltageshouldbebetween130 to275V. BIS Approved and Tested by NABL/CPRI accredited laboratory with 2 years Warranty against any manufacturing defect working under standard electrical condition.</p>	nos	20

-Sd-

Managing Director,
Hubballi Dharwad Smart City Limited
Hubballi